

230 Crescent Avenue
Chelsea, Ma.

NO. 6 FUEL OIL

Lab Reference	99940015	Classification	Tk 1
Vessel/Barge	B-95	Grade	#6 Fuel Oil
Client	Sprague	Terminal	Bucksport ME
Date on Sample	1/5/04	Sampled by	Ray
Date Tested	1/5/04	Tested by	AC/RG

Tests	Method	Results	Unit of Measure
API Gravity @ 60°F	D-4052	12.7	API
Flash Point, PMCC	D-93B	203	Degrees F
Pour Point/Upper	D-97	3 / 37	Degrees C/F
Sulfur Content	D-4294	1.84	Weight %
S&W Content	D-1796	0.30	Volume %
Viscosity	D-445	269.8	Cst
Viscosity @ 122F	D-2161	127.5	Sfs
Ash Content	D-482	0.063	Weight %
Heat of Combustion	D-240	18384	Btu/lb
Gravity	Table 8	8.172	lb./gal
Heat of Combustion	D-240	150234	Btu/Gal.
Nitrogen	D-5762	0.29	Weight %
Vanadium	D5863B	162	Ppm
Sodium	D5863B	21	Ppm
Water by Distillation	D-95	0.30	Volume %
Sediment by Extraction	D-473	0.05	Weight %
Asphaltenes	IP-143	3.5	Weight %
Conradson Carbon Residue	D-189	10.4	Weight %

Approved

Sprague's N6 Slate.

SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.